



(T) 0312 394 0 555 (F) 0312 394 0 808

# KABLO SEÇİM CETVELİ

## DİREK KALKIŞ

GÜÇ		V O L T A J	KABLO KESİTİ 3 x .... mm <sup>2</sup>									
HP	kW		1,5	2,5	4	6	10	16				
MAKSİMUM UZUNLUK ( METRE )												
0,5	0,37	220 V	80	130								
0,75	0,55		55	90	140							
1	0,75		40	80	105	160						
1,5	1,10		30	50	75	115	190					
2	1,50		20	35	60	90	145	235				
3	2,20		30	50	70	120	185					

GÜÇ		V O L T A J	KABLO KESİTİ 3 x .... mm <sup>2</sup>											
HP	kW		2,5	4	6	10	16	25	35	50	70	95	120	150
MAKSİMUM UZUNLUK ( METRE )														
3	2,2	380 V	190	300	460									
4	3		150	240	360									
5,5	4		110	170	260	450								
7,5	5,5		80	130	190	340	540							
10	7,5		60	100	150	250	410							
12,5	9,2		50	80	120	205	330	510						
15	11			60	100	170	280	440						
17,5	13				90	150	245	385						
20	15				80	130	210	330	460	660				
25	18,5					100	170	260	370	530				
30	22					90	140	220	310	440				
35	26						120	190	270	380	540			
40	30						100	170	230	330	460			
50	37							130	190	270	380	520		
60	45							110	160	230	320	440	550	
70	52								140	200	280	385	480	
75	55								120	170	240	330	410	530
80	59								115	160	230	310	390	500
90	66								110	150	220	290	370	470
100	75								96	140	190	270	330	425
110	81								125	175	245	300	380	
125	92								110	160	220	275	340	
150	110								130	180	220	290		
180	132									150	190	240		
200	150									130	170	220		
225	165									125	150	190		
250	185											170		
275	200												160	

TABLODA BELİRTİLEN MAKSİMUM KABLO UZUNLUKLARI %3' LÜK VOLTAJ DÜŞMESİ

TEMEL ALINARAK VE 25 °C SICAKLIKTA HESAPLANMIŞTIR.



(T) 0312 394 0 555 (F) 0312 394 0 808

# KABLO SEÇİM CETVELİ

## YILDIZ ÜÇGEN

GÜÇ		V O L T A J	KABLO KESİTİ 3 x .... mm <sup>2</sup>												
HP	kW		1,5	2,5	4	6	10	16	25	35	50	70	95	120	150
MAKSİMUM UZUNLUK ( METRE )															
4	3	380 V	140	230	370										
5,5	4		100	170	270	400									
7,5	5,5		70	120	200	300	500								
10	7,5		57	90	150	220	380								
12,5	9,2		46	70	120	180	310	490							
15	11		39	60	100	150	260	400							
17,5	13			55	90	130	230	355							
20	15			50	80	110	200	310	490						
25	18,5				60	90	160	250	400	560					
30	22				50	70	130	210	340	470					
35	26				46	68	110	180	290	410					
40	30					60	100	160	250	360	500				
50	37					40	80	130	200	290	410				
60	45						70	110	170	240	350	480			
70	52							95	150	210	305	420			
75	55							80	130	180	260	360	500		
80	59								120	170	245	340	475		
90	66								110	160	230	320	450	520	
100	75								100	150	200	290	380	440	540
110	81									135	185	260	340	405	495
125	92									120	170	230	300	370	450
150	110									100	140	200	250	300	370
180	132										120	165	210	260	310
200	150											150	190	230	280
225	165											130	170	200	240
250	185											125	160	190	230
275	200												140	170	200
300	220													120	

TABLODA BELİRTİLEN MAKSİMUM KABLO UZUNLUKLARI %3' LÜK VOLTAJ DÜŞMESİ

TEMEL ALINARAK VE 25 °C SICAKLIKTA HESAPLANMIŞTIR.